



# Certificate of compliance

**Applicant:** Huawei Technologies Co., Ltd.  
Administration Building, Headquarters of Huawei Technologies Co., Ltd.,  
Bantian, Longgang District, Shenzhen, 518129  
P.R.C

**Product:** SOLAR INVERTER

**Model:** SUN2000-8KTL-M0, SUN2000-10KTL-M0,  
SUN2000-12KTL-M0, SUN2000-15KTL-M0,  
SUN2000-17KTL-M0, SUN2000-20KTL-M0,  
SUN2000-8KTL-M2, SUN2000-10KTL-M2,  
SUN2000-12KTL-M2, SUN2000-15KTL-M2,  
SUN2000-17KTL-M2, SUN2000-20KTL-M2

## Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with EN 50438:2013 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

## Zkušební podklady:

**EN 50438:2013, ČSN EN 50438:2014**

Requirements for micro-generating plants to be connected in parallel with public low-voltage distribution networks

**DIN V VDE V 0126-1-1 (VDE V 0126-1-1):2006-02 (Functional safety)**

Automatic disconnection device between a generator and the public low-voltage grid

**Pravidla Provozování, Distribučních Soustav, Příloha 4 2017**

Rules for parallel operation of Generators and Storage System with the Network Operator Distribution System

The generator(s) SUN2000-10KTL-M0, SUN2000-12KTL-M0, SUN2000-15KTL-M0, SUN2000-17KTL-M0, SUN2000-20KTL-M0, SUN2000-10KTL-M2, SUN2000-12KTL-M2, SUN2000-15KTL-M2, SUN2000-17KTL-M2, SUN2000-20KTL-M2 are rated >16A per phase. However all requirements of the EN 50438:2013 are fulfilled.

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

**Report number:** PVCZ190424N048

**Certificate number:** U19-0357

**Date of issue:** 2019-06-07



Certification body of Bureau Veritas Consumer Products Services Germany GmbH  
Accredited according to DIN EN ISO/IEC 17065